



Section I--Violation Data

1. Date Mo Da Yr 12/06/2011	2. Time (24 Hr. Clock) 0800	3. Citation/ Order Number 4900276
4. Served To Berman Cornett (Safety Director)		5. Operator PERFORMANCE COAL COMPANY, et al
6. Mine UPPER BIG BRANCH MINE-SOUTH		7. Mine ID 46-08436 (Contractor)
8. Condition or Practice		8a. Written Notice (103g) <input type="checkbox"/>

The dry chemical fire suppression system, installed on the Ingersol Rand "Maintenance" scoop (serial #488-1253, located on HG22) is not being properly maintained, in that;

(1) the nozzles are not provided with protective caps to prevent the entrance of dirt/moisture, and

(2) the actuator cartridge on the off-side of the machine is not an Ansul cartridge as per the manufacturer's requirements.

This machine is located in an area affected by a mine explosion on 04.05.2010. The Operator is issued a high number of similar citations, upon inspection of the electrical equipment, following the explosion.

See Continuation Form (MSHA Form 7000-3a)

9. Violation	A. Health Safety <input checked="" type="checkbox"/> Other <input type="checkbox"/>	B. Section of Act	C. Part/Section of Title 30 CFR 75.1107-9(a)(1)
--------------	---	-------------------	--

Section II--Inspector's Evaluation

10. Gravity:						
A. Injury or Illness (has) (is):		No Likelihood <input type="checkbox"/>	Unlikely <input checked="" type="checkbox"/>	Reasonably Likely <input type="checkbox"/>	Highly Likely <input type="checkbox"/>	Occurred <input type="checkbox"/>
B. Injury or illness could reasonably be expected to be:		No Lost Workdays <input type="checkbox"/>	Lost Workdays Or Restricted Duty <input checked="" type="checkbox"/>	Permanently Disabling <input type="checkbox"/>	Fatal <input type="checkbox"/>	
C. Significant and Substantial:			Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	D. Number of Persons Affected: 002	
11. Negligence (check one)						
A. None <input type="checkbox"/>		B. Low <input type="checkbox"/>		C. Moderate <input type="checkbox"/>		D. High <input checked="" type="checkbox"/>
E. Reckless Disregard <input type="checkbox"/>						
12. Type of Action 104(a)			13. Type of Issuance (check one)			
			Citation <input checked="" type="checkbox"/>		Order <input type="checkbox"/>	Safeguard <input type="checkbox"/>
			Written Notice <input type="checkbox"/>			
14. Initial Action				E. Citation/ Order Number		F. Dated Mo Da Yr
A. Citation <input type="checkbox"/>		B. Order <input type="checkbox"/>		C. Safeguard <input type="checkbox"/>		D. Written Notice <input type="checkbox"/>

15. Area or Equipment

16. Termination Due	A. Date Mo Da Yr 01/05/2012	B. Time (24 Hr. Clock) 0800
---------------------	--------------------------------	--------------------------------

Section III--Termination Action

17. Action to Terminate

18. Terminated	A. Date Mo Da Yr	B. Time (24 Hr. Clock)
----------------	------------------	------------------------

Section IV--Automated System Data

19. Type of Inspection (activity code) E16	20. Event Number 4440348	21. Primary or Mill
22. Signature Patrick Alan Stanfield		23. AR Number 23908



Section I--Subsequent Action/Continuation Data

1. Subsequent Action 1a. Continuation <input type="checkbox"/> <input checked="" type="checkbox"/>	2. Dated (Original Issue)	Mo Da Yr 12/06/2011	3. Citation/ Order Number	4900276
4. Served To Berman Cornett (Safety Director)			5. Operator PERFORMANCE COAL COMPANY, et al	
6. Mine UPPER BIG BRANCH MINE-SOUTH			7. Mine ID 46-08436 (Contractor)	

Section II--Justification for Action

Continuation of 8. Condition or Practice

This citation is being issued to the following entities as a unitary operator: Performance Coal Company, Massey Coal Services, Inc., A.T. Massey Coal Company, Inc., and Massey Energy Company.

See Continuation Form

Section III--Subsequent Action Taken

8. Extended To	A. Date	Mo Da Yr	B. Time (24 Hr. Clock)	<input type="checkbox"/> C. Vacated	<input type="checkbox"/> D. Terminated	<input type="checkbox"/> E. Modified
----------------	---------	----------	------------------------	-------------------------------------	--	--------------------------------------

Section IV--Inspection Data

9. Type of Inspection	E16	10. Event Number	4440348
11. Signature	AR Number	12. Date	13. Time (24 Hr. Clock)
Patrick Alan Stanfield	23908	12/06/2011	0800