



Section I--Violation Data

1. Date Mo Da Yr 12/06/2011	2. Time (24 Hr. Clock) 0800	3. Citation/ Order Number 4900495
4. Served To Berman Cornett (Safety Director)		5. Operator Performance Coal Company, et al.
6. Mine UPPER BIG BRANCH MINE-SOUTH		7. Mine ID 46-08436 (Contractor)
8. Condition or Practice		8a. Written Notice (103g) <input type="checkbox"/>

The dry chemical fire suppression system on the Fairchild scoop, S/N T339-267, on the TG22 section was not being maintained in functional condition. The following conditions were observed:

- 1) there were only three nozzles attached to the system.
- 2) the bursting disc in the dry chemical tank was missing.
- 3) wet and compacted chemical was present in the fitting and hose attached to the bottom of the chemical tank.
- 4) the distribution hoses and fittings were not properly installed.

This citation is being issued to the following entities as a unitary operator: Performance Coal Company, Massey Coal Services, Inc., A.T. Massey Coal Company, Inc., and Massey Energy Company.

See Continuation Form (MSHA Form 7000-3a)

9. Violation	A. Health <input type="checkbox"/> Safety <input checked="" type="checkbox"/> Other <input type="checkbox"/>	B. Section of Act	C. Part/Section of Title 30 CFR 75.1107-16(b)
--------------	--	-------------------	--

Section II--Inspector's Evaluation

10. Gravity:

A. Injury or Illness (has) (is): No Likelihood Unlikely Reasonably Likely Highly Likely Occurred

B. Injury or illness could reasonably be expected to be: No Lost Workdays Lost Workdays Or Restricted Duty Permanently Disabling Fatal

C. Significant and Substantial: Yes No

D. Number of Persons Affected: 010

11. Negligence (check one) A. None B. Low C. Moderate D. High E. Reckless Disregard

12. Type of Action 104(a) 13. Type of Issuance (check one) Citation Order Safeguard Written Notice

14. Initial Action A. Citation B. Order C. Safeguard D. Written Notice E. Citation/Order Number F. Dated Mo Da Yr

15. Area or Equipment

16. Termination Due A. Date Mo Da Yr 01/05/2012 B. Time (24 Hr. Clock) 0800

Section III--Termination Action

17. Action to Terminate

18. Terminated A. Date Mo Da Yr B. Time (24 Hr. Clock)

Section IV--Automated System Data

19. Type of Inspection (activity code) E16 20. Event Number 4440348 21. Primary or Mill

22. Signature Keith McElroy 23. AR Number 24153