



Section I—Violation Data

1. Date Mo Da Yr 12/06/2011	2. Time (24 Hr. Clock) 0800	3. Citation/ Order Number 8258598
4. Served To Berman Cornett (Safety Director)	5. Operator PERFORMANCE COAL COMPANY, et al	
6. Mine UPPER BIG BRANCH MINE-SOUTH	7. Mine ID 46-08436	(Contractor)
8. Condition or Practice		8a. Written Notice (103g) <input type="checkbox"/>

Terminations in accordance with the manufacturer's specification (3M) have not been made in the ends of the 4/0 high voltage entered into the AEEI (American Electric Equipment, Inc) #7 North Starter/transformer (serial #22040-2300-206). The shielding over the individual conductors is not connected to a ground. The starter/transformer is located at Crosscut 105 of the North Mains.

The equipment is located in an area affected by an explosion on 04.05.2010. The operator is issued a high number of similar citations upon inspection of the underground electrical equipment, following the explosion.

This citation is being issued to the following entities as a unitary

See Continuation Form (MSHA Form 7000-3a)

9. Violation	A. Health Safety <input checked="" type="checkbox"/> Other <input type="checkbox"/>	B. Section of Act	C. Part/Section of Title 30 CFR 75.810
--------------	---	-------------------	---

Section II—Inspector's Evaluation

10. Gravity:				
A. Injury or Illness (has) (is): No Likelihood <input type="checkbox"/> Unlikely <input checked="" type="checkbox"/> Reasonably Likely <input type="checkbox"/> Highly Likely <input type="checkbox"/> Occurred <input type="checkbox"/>				
B. Injury or illness could reasonably be expected to be: No Lost Workdays <input type="checkbox"/> Lost Workdays Or Restricted Duty <input checked="" type="checkbox"/> Permanently Disabling <input type="checkbox"/> Fatal <input type="checkbox"/>				
C. Significant and Substantial: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>				D. Number of Persons Affected: 001
11. Negligence (check one) A. None <input type="checkbox"/> B. Low <input type="checkbox"/> C. Moderate <input type="checkbox"/> D. High <input checked="" type="checkbox"/> E. Reckless Disregard <input type="checkbox"/>				
12. Type of Action 104(a)		13. Type of Issuance (check one) Citation <input checked="" type="checkbox"/> Order <input type="checkbox"/> Safeguard <input type="checkbox"/> Written Notice <input type="checkbox"/>		
14. Initial Action A. Citation <input type="checkbox"/> B. Order <input type="checkbox"/> C. Safeguard <input type="checkbox"/> D. Written Notice <input type="checkbox"/>			E. Citation/ Order Number	F. Dated Mo Da Yr

15. Area or Equipment

16. Termination Due	A. Date Mo Da Yr 01/05/2012	B. Time (24 Hr. Clock) 0800
---------------------	-----------------------------------	--------------------------------

Section III—Termination Action

17. Action to Terminate

18. Terminated	A. Date Mo Da Yr	B. Time (24 Hr. Clock)
----------------	---------------------	------------------------

Section IV—Automated System Data

19. Type of Inspection (activity code) E16	20. Event Number 4440348	21. Primary or Mill
22. Signature Patrick Alan Stanfield		23. AR Number 23908

Mine Citation/Order  
Continuation

U.S. Department of Labor  
Mine Safety and Health Administration



Section I—Subsequent Action/Continuation Data

1. Subsequent Action 1a. Continuation <input type="checkbox"/> <input checked="" type="checkbox"/>	2. Dated (Original Issue) Mo Da Yr 12/06/2011	3. Citation/ Order Number 8258598
---	---	--------------------------------------

4. Served To Berman Cornett (Safety Director)	5. Operator PERFORMANCE COAL COMPANY, et al
--	--

6. Mine UPPER BIG BRANCH MINE-SOUTH	7. Mine ID 46-08436 (Contractor)
--	-------------------------------------

Section II—Justification for Action

Continuation of 8. Condition or Practice

operator: Performance Coal Company, Massey Coal Services, Inc., A.T. Massey Coal Company, Inc., and Massey Energy Company.

See Continuation Form

Section III—Subsequent Action Taken

8. Extended To	A. Date Mo Da Yr	B. Time (24 Hr. Clock)	<input type="checkbox"/> C. Vacated	<input type="checkbox"/> D. Terminated	<input type="checkbox"/> E. Modified
----------------	------------------	------------------------	-------------------------------------	--	--------------------------------------

Section IV—Inspection Data

9. Type of Inspection E16	10. Event Number 4440348
---------------------------	--------------------------

11. Signature Patrick Alan Stanfield	AR Number 23908	12. Date Mo Da Yr 12/06/2011	13. Time (24 Hr. Clock) 0800
---	--------------------	---------------------------------	---------------------------------