

Hand Tools & Shop

Started 3-31-10

**EXAMINATION OF
ELECTRICAL EQUIPMENT**

Company _____

Mine _____

Location _____

Post Office

County

State

Re-order from
**BJW Printing and
Office Supplies**
P. O. Box 1309
Beckley, W. Va. 25801
Phone (304) 253-7361

Form 6—1492
(March 1970)

Budget Bureau No. 42-R1589
Approval expires 9-30-71

When this book is completed it shall be retained at the mine for a period of one year after the date of the last entry in the book, regardless of change of ownership. When a mine is temporarily closed or abandoned, the operator shall retain this book in a safe place during the period of closure or for a period of one year after the mine is abandoned. This book is approved by the Director of The West Virginia Department of Mines and The U. S. Bureau of Mines.

Vertical text on the right edge of the page, possibly a page number or reference code, appearing as a series of vertical lines and characters.

EXAMINATION OF ELECTRICAL EQUIPMENT

Examination of electrical equipment (weekly)

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Examiner
3-31-10	Shop	Shop	overhead FAN down Taken out of Service		Raity 4-20-10
3-31-10	Shop	Crane	None Found		Raity 4-20-10
3-31-10	Shop	Air Compressor	None Found		Raity 4-20-10
3-31-10	Shop	4" & 9" Grinders	None Found		Raity 4-20-10
Weekly tests of grounding devices (diodes)					
3-31-10	Shop	2 Ext Cord	Tested OK		Raity 4-20-10
3-31-10	Shop	1 Welder	None Found		Raity 4-20-10
3-31-10	Bath house	Water Heaters	None Found		Raity 4-20-10
3-31-10	Shop	1/2 impact	None Found		Raity 4-20-10
3-31-10	Shop	2+3 Fans	None Found		Raity 4-20-10
3-31-10	Shop	1+2 Power box	None Found		Raity 4-20-10
Monthly examinations of methane monitors					
3-31-10	Shop	Magnetic & Hand Drill	None Found		Raity 4-20-10
3-31-10	Shop	Bandsaw	None Found		Raity 4-20-10

EXAMINATION OF ELECTRICAL EQUIPMENT

Power centers and transformers prior to movement

Date	Location	Equipment examined and/or tested	Dangerous conditions	Action taken	Inspector
4-9-10	Shop	Band Saw	None Found		Kathy
4-9-10	Shop	1/2 impact	None Found		Kathy
4-9-10	Shop	Magnetic Hand Drill	None Found		Kathy
4-9-10	Shop	1 Welder	None Found		Kathy
4-9-10	Bathhouse	Water Heaters	None Found		Kathy
4-9-10	Shop	Shop #2 GFI bad Cables in the Shop - Misc Emergency	Corrected		Kathy
4-9-10	Shop	2 Ext. Cord missing from Shop			Kathy
4-9-10	Shop	1st Power Center #2 GFI bad Cables in the Shop - Misc Emergency	Corrected		Kathy
<small>Examinations of low-medium voltage power circuit breakers (monthly)</small>					
4-9-10	Shop	4" & 9" Grinders	None Found		Kathy
4-9-10	Shop	Crane	None Found		Kathy
4-9-10	Shop	Air Compressor	None Found		Kathy