

Fatality Alert

MINE FATALITY – On July 26, 2025, an electrician was electrocuted when he came in contact with one phase of a 13,200-volt three phase power source.



Best Practices

- Always lock out, tag out, and try out electrical equipment prior to work.
- Verify circuits are de-energized using properly rated test equipment.
- Leave protective covers in place until electrically powered equipment is de-energized.
- Always ensure High Voltage equipment conductors are grounded before beginning work.
- Always use proper tools and Personal Protective Equipment when working with electricity.

This is the 16th fatality reported in 2025, and the first classified as “Electrical.”

The information provided in this notice is based on preliminary information only and does not represent final determinations regarding the nature of the accident or conclusions regarding the cause of the fatality.

Report accidents and hazardous conditions: 1-800-746-1553

[msha.gov](https://www.msha.gov) | askmsa@dol.gov | [@MSHA_DOL](https://twitter.com/MSHA_DOL)