MNM Fatal 2011-09

Electrical Accident
September 13, 2011 (Washington)
Sand & Gravel Operation
Quality Control Person
38 years old
3 years of experience

Overview

The victim was killed , while working on an energized electrical circuit. He was attempting to reverse the polarity on an energized power cable at a control trailer when he received a fatal electrical shock.

The accident occurred because management procedures failed to ensure that persons deenergize an electrical circuit prior to performing work on it. The system was not locked out, tagged out, or tested to verify it was de-energized.



Root Cause

Root Cause: Management policies and procedures failed to ensure that persons were specifically trained to verify that electrical circuits were de-energized and locked out prior to performing work on them.

Corrective Action: Mine management implemented a Standard Operating Program including a new lock out, tag out, and verification system for all of their portable operations. All persons have been trained regarding the new policies and procedures. A company electrician will be at the site any time a plant is set-up, taken down, or when electrical work is performed to ensure that all safety procedures are followed.

Best Practices

- Be trained on all the electrical tests and safety equipment necessary to safely test and ground the circuit being worked on.
- Conduct a risk assessment.
- Use properly rated Personal Protective Equipment (PPE) including Arc Flash Protection such as a hood, gloves, shirt, and pants.
- Positively identify the circuit on which work is to be conducted.
- De-energize power and ensure that the circuit is visibly open.

Best Practices

Place YOUR lock and tag on the disconnecting device.

- Verify the circuit is de-energized by testing for voltage using properly rated test equipment.
- Ensure ALL electrical components in the enclosure are de-energized.
- Ground ALL phase conductors to the equipment grounding medium with grounding equipment that is properly rated.